

NOTES: ENGLERT TRANSITION FLASHING SHALL HAVE 6" MIN. OVERLAP w/ 2 ROWS OF ENGLERT BUTYL TAPE SEALANT FASTENED w/ COLOR MATCHED HEX SCREWS w/ BONDED SEALING WASHER PER PROJECT REQUIREMENTS. TRANSITION SUPPORT PLATE, WHEN REQUIRED, SHALL EXTEND TO Z-CLOSURE.

(2) ROWS $\frac{3}{8}$ " ENGLERT IN-SEAM TUBE SEALANT (TYP.)
 ENGLERT OFFSET CLEAT CONTINUOUS (TYP.)
 PANCAKE SCREW PER PROJECT REQUIREMENTS (TYP.)
 ENGLERT BUTYL TAPE SEALANT CONTINUOUS (TYP.)
 INSTALL ENGLERT TUBE SEALANT BEFORE INSERTING PANEL HEM (TYP.)

PANCAKE SCREW PER PROJECT REQUIREMENTS @ 3" O.C. MAX. THRU Z-CLOSURE (TYP.)
 ENGLERT Z-CLOSURE CUT TO FIT BETWEEN SEAMS w/ ENGLERT TUBE SEALANT ON ALL CUT EDGES (TYP.)
 COLOR MATCHED HEX SCREW w/ BONDED SEALING WASHER
 ENGLERT BUTYL TAPE SEALANT CONTINUOUS (TYP.)
 ENGLERT CLIP (SEE DETAIL R02)
 ROOF ASSEMBLY (SEE DETAIL R08)
 ENGLERT TRANSITION FLASHING
 20 GA MIN. TRANSITION SUPPORT PLATE REQUIRED WHEN L > 4"
 BREAD PAN FOLD
 L
 ROOF ASSEMBLY (SEE DETAIL R08)

6" MAX. (TYP.)

1" MIN. 1" MIN.

1" MIN. OPEN HEM

1" MIN. SEAM + 1/8" 1" MIN.

ENGLERT
 www.englertinc.com
 800-364-5378

**ROOF TRANSITION
 PITCH BREAK**

DETAIL SUBJECT TO CHANGE WITHOUT NOTICE.

Detail #
R34.1

GENERIC BEST PRACTICE ASSEMBLY SHOWN. WATERTIGHTNESS WARRANTY NOT IMPLIED. WHEN SITE CONDITION DIFFERS, SPECIFIC ENGINEERING NECESSARY.